



Lindop School District 202

Drinking Fountains & Sink Faucets Water Sampling Summary and Results

LINDOP ELEMENTARY SCHOOL

Mr. Dajuan Ballentine
Buildings and Grounds
LINDOP SCHOOL DISTRICT 92
2400 18th Avenue
Broadview, IL 60155

ENVIRONMENTAL SERVICES, INC. (ESI) performed “First Draw” potable water sampling and “Second Draw” potable water sampling after running each regulated water source for 30 seconds. This sampling included operable hand washing and food preparation sink faucets in classrooms, work areas, and kitchens. The Illinois Code only mandates sampling the hand washing sinks in Classroom / Toilet Rooms used by students younger than 1st Grade. Each sample was obtained by an Environmental Health Engineer or Field Specialist and analyzed for Lead contamination by an Illinois EPA certified laboratory. The State of Illinois protocols and standards were applied.

Results Summary:

All operable drinking water sources sampled meet the State of Illinois standard of 5 ug/L (micrograms per Liter [parts per billion]) or less and the EPA action level standard of 15 ug/L. Operable Drinking Fountain, Bottle Fill Stations, Consumed Water faucets, and Classroom Sink Faucets were sampled in Classrooms throughout this facility.

This facility is regulated by the Illinois Code, Public Act 099-0922 because it was constructed before 01 January 2000 and serves students 5th Grade and younger.

Recommendations:

- R1. No follow-up sampling is required or recommended for this facility.
- R2. As District personnel have done in the past, continue to respond to Parent, Staff, and Student drinking water concerns.

If there are any questions, if additional information is requested, if additional follow-up sampling is requested, or if you would like to meet to discuss the results, please contact me.

ENVIRONMENTAL SERVICES, INC.

Nick Malone

Nick Malone, P.E.
M.S. Environmental Health Engineering

Analytical Report and Sampling Floor Plan Attached

NJM/ww2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

December 15, 2017

Nick Malone
Environmental Services Inc
1415 W. 55th - suite 201
Countryside, IL 60534

Workorder: 1712017

TEL: (708) 354-7121

FAX:

RE: SD92 Lindop Drinking Water Lead Analysis

Dear Nick Malone:

Suburban Laboratories, Inc. received 3 sample(s) on 12/1/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: December 15, 2017

Project Name: SD92 Lindop Drinking Water Lead Analysis

Workorder: 1712017

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1712017-001A	L 48.1~1st Draw CW~First Draw	ND	2.00	µg/L	11/30/2017 16:00	12/1/2017	12/14/2017
1712017-002A	L 48.2~2nd Draw CW~Flush	ND	2.00	µg/L	11/30/2017 16:00	12/1/2017	12/14/2017
1712017-003A	L 48.3~1st Draw HW~First Draw	ND	2.00	µg/L	11/30/2017 16:00	12/1/2017	12/14/2017

1712017-001A-003A

FIELD DATA FORM

School/Facility Name
Lindop SD 92
ISBE ID: (ex:01-001-0001-01-00001)

Address
Environmental Services, Inc.
P.O. BOX 688
LaGrange, IL 60525-0688
MMDDYY

Sample Collector Name(s)
KP

Water system last used Date: 11/30/2017 Time: 16:00

All samples must be collected in unpreserved 250 ml plastic bottles

	Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
Ex1:	0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" is selected
Ex2:	0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1	0001	Main Building	L48.1	1st Draw CW	12/01/2017	6:55	S - Sink	First Draw	250	Room 115
2	0001	Main Building	L48.2	2nd Draw CW	12/01/2017	6:55	S - Sink	Flush	250	
3	0001	Main Building	L48.3	1st Draw HW	12/01/2017	6:55	S - Sink	First Draw	250	
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31									250	
32									250	
33									250	
34									250	
35									250	
36									250	
37									250	
38									250	
39									250	
40									250	
41									250	
42									250	
43									250	
44									250	
45									250	
46									250	
47									250	
48									250	
49									250	
50									250	
51									250	
52									250	
53									250	
54									250	
55									250	
56									250	
57									250	
58									250	

Kevin Ga... 12/1/17 10:52 *Karalayne* 12-1-17 Page 3 of 3

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: August 23, 2017

Project Name: ESI 5271 Lindop 92 Drinking Water Lead Analysis

Workorder: 1708C18

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1708C18-001A	LI 42.1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-002A	LI 42.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-003A	LI 42.3~1st Draw HW~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-004A	LI 48.1~1st Draw CW ~First Draw	13.4	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-005A	LI 48.2~2nd Draw CW~Flush	12.3	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-006A	LI 49.1~1st Draw CW ~First Draw	2.13	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-007A	LI 49.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-008A	LI 50.1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-009A	LI 50.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-010A	LI 51.1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-011A	LI 51.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-012A	LI 52.1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-013A	LI 52.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-014A	LI 53.1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-015A	LI 53.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-016A	LI 54.1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-017A	LI 54.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-018A	LI 54.3~1st Draw HW~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-019A	LI 54-RO1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-020A	LI 54-RO2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-021A	LI 55.1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-022A	LI 55.2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-023A	LI 55.3~1st Draw HW~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017
1708C18-024A	LI 55-RO1~1st Draw CW ~First Draw	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: August 23, 2017

Project Name: ESI 5271 Lindop 92 Drinking Water Lead Analysis

Workorder: 1708C18

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1708C18-025A	LI 55-RO2~2nd Draw CW~Flush	ND	2.00	µg/L	08/14/17 00:01	8/15/2017	8/22/2017

1708 C18

25

FIELD DATA FORM

School/Facility Name
Lindop 92 - ESI #5271
ISBE ID: (ex:01-001-0001-01-00001)

Address
Environmental Services, Inc.
P.O. BOX 688
LaGrange, IL 60525

Sample Collector Name(s)
KP

Water system last used Date: 08/14/2017 Time: 0:01

All samples must be collected in unpreserved

Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" is selected
0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1		LI 42.1	1st Draw CW	08/15/2017	7:00	S - Sink	First Draw	250	
2		LI 42.2	2nd Draw CW	08/15/2017	7:00	S - Sink	Flush	250	
3		LI 42.3	1st Draw HW	08/15/2017	7:00	S - Sink	First Draw	250	
4		LI 48.1	1st Draw CW	08/15/2017	7:05	S - Sink	First Draw	250	Combo Sink
5		LI 48.2	2nd Draw CW	08/15/2017	7:05	S - Sink	Flush	250	Combo Sink
6		LI 49.1	1st Draw CW	08/15/2017	7:07	S - Sink	First Draw	250	Combo Sink
7		LI 49.2	2nd Draw CW	08/15/2017	7:07	S - Sink	Flush	250	Combo Sink
8		LI 50.1	1st Draw CW	08/15/2017	7:09	S - Sink	First Draw	250	Combo Sink
9		LI 50.2	2nd Draw CW	08/15/2017	7:09	S - Sink	Flush	250	Combo Sink
10		LI 51.1	1st Draw CW	08/15/2017	7:11	S - Sink	First Draw	250	Combo Sink
11		LI 51.2	2nd Draw CW	08/15/2017	7:11	S - Sink	Flush	250	Combo Sink
12		LI 52.1	1st Draw CW	08/15/2017	7:12	S - Sink	First Draw	250	Combo Sink
13		LI 52.2	2nd Draw CW	08/15/2017	7:12	S - Sink	Flush	250	Combo Sink
14		LI 53.1	1st Draw CW	08/15/2017	7:13	S - Sink	First Draw	250	Combo Sink
15		LI 53.2	2nd Draw CW	08/15/2017	7:13	S - Sink	Flush	250	Combo Sink
16		LI 54.1	1st Draw CW	08/15/2017	7:16	S - Sink	First Draw	250	
17		LI 54.2	2nd Draw CW	08/15/2017	7:16	S - Sink	Flush	250	
18		LI 54.3	1st Draw HW	08/15/2017	7:16	S - Sink	First Draw	250	
19		LI 54-RO1	1st Draw CW	08/15/2017	7:17	O - Other	First Draw	250	REVERSE OSMOSSIS
20		LI 54-RO2	2nd Draw CW	08/15/2017	7:17	O - Other	Flush	250	REVERSE OSMOSSIS
21		LI 55.1	1st Draw CW	08/15/2017	7:20	S - Sink	First Draw	250	
22		LI 55.2	2nd Draw CW	08/15/2017	7:20	S - Sink	Flush	250	
23		LI 55.3	1st Draw HW	08/15/2017	7:20	S - Sink	First Draw	250	
24		LI 55-RO1	1st Draw CW	08/15/2017	7:21	O - Other	First Draw	250	REVERSE OSMOSSIS
25		LI 55-RO2	2nd Draw CW	08/15/2017	7:21	O - Other	Flush	250	REVERSE OSMOSSIS
26									
27									
28									
29									
30									
31									
32									
33									
34									
35									
36									
37									
38									
39									
40									
41									
42									
43									
44									
45									
46									
47									
48									
49									
50									
51									
52									
53									
54									
55									
56									
57									

Relinquished 8-15-17 10:50 KP Received 8-15-17 10:50 Page 4 of 4

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: August 10, 2017

Project Name: ESI # 5271 Lindop 92 Drinking Water Lead Analysis

Workorder: 1708227

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1708227-001A	LI 1.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-002A	LI 1.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-003A	LI 1.3~1st Draw HW ~First Draw	2.79	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-004A	LI 2.1~1st Draw CW ~First Draw	4.98	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-005A	LI 2.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-006A	LI 3.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-007A	LI 3.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-008A	LI 3.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-009A	LI 4.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-010A	LI 4.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-011A	LI 5.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-012A	LI 5.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-013A	LI 5.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-014A	LI 6.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-015A	LI 6.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-016A	LI 7.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-017A	LI 7.2~2nd Draw CW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-018A	LI 8.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-019A	LI 8.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-020A	LI 8.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-021A	LI 9.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-022A	LI 9.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-023A	LI 10.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-024A	LI 10.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: August 10, 2017

Project Name: ESI # 5271 Lindop 92 Drinking Water Lead Analysis

Workorder: 1708227

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1708227-025A	LI 10.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-026A	LI 11.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-027A	LI 11.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-028A	LI 12.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-029A	LI 12.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-030A	LI 12.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-031A	LI 13.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-032A	LI 13.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-033A	LI 14.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-034A	LI 14.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-035A	LI 14.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-036A	LI 15.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-037A	LI 15.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-038A	LI 16.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-039A	LI 16.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-040A	LI 16.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-041A	LI 17.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-042A	LI 17.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-043A	LI 18.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-044A	LI 18.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-045A	LI 18.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-046A	LI 19.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-047A	LI 19.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-048A	LI 20.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: August 10, 2017

Project Name: ESI # 5271 Lindop 92 Drinking Water Lead Analysis

Workorder: 1708227

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1708227-049A	LI 20.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-050A	LI 20.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-051A	LI 21.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-052A	LI 21.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-053A	LI 22.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-054A	LI 22.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-055A	LI 22.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-056A	LI 23.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-057A	LI 23.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-058A	LI 24.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-059A	LI 24.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-060A	LI 24.3~1st Draw HW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/9/2017
1708227-061A	LI 25.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-062A	LI 25.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-063A	LI 28.1~1st Draw CW ~First Draw	28.9	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-064A	LI 28.2~2nd Draw CW~Flush	5.31	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-065A	LI 28.3~1st Draw HW~First Draw	2.61	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-066A	LI 29.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-067A	LI 29.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-068A	LI 29.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-069A	LI 30.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-070A	LI 30.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-071A	LI 30.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-072A	LI 31.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: August 10, 2017

Project Name: ESI # 5271 Lindop 92 Drinking Water Lead Analysis

Workorder: 1708227

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1708227-073A	LI 31.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-074A	LI 31.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-075A	LI 32.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-076A	LI 32.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-077A	LI 33.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-078A	LI 33.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-079A	LI 33.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-080A	LI 34.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-081A	LI 34.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-082A	LI 34.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-083A	LI 35.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-084A	LI 35.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-085A	LI 35.3~1st Draw HW~First Draw	2.71	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-086A	LI 36.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-087A	LI 36.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-088A	LI 36A.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-089A	LI 36A.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-090A	LI 36B.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-091A	LI 36B.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-092A	LI 37.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-093A	LI 37.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-094A	LI 37.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-095A	LI 38.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-096A	LI 38.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Environmental Services Inc

Report Date: August 10, 2017

Project Name: ESI # 5271 Lindop 92 Drinking Water Lead Analysis

Workorder: 1708227

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1708227-097A	LI 39.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-098A	LI 39.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-099A	LI 40.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-100A	LI 40.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-101A	LI 41.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-102A	LI 41.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-103A	LI 44.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-104A	LI 44.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-105A	LI 45.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-106A	LI 45.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-107A	LI 45.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-108A	LI 46.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-109A	LI 46.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-110A	LI 46.3~1st Draw HW~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-111A	LI 47.1~1st Draw CW ~First Draw	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017
1708227-112A	LI 47.2~2nd Draw CW~Flush	ND	2.00	µg/L	7/31/2017 16:00	8/1/2017	8/7/2017

170827-001A-112A

FIELD DATA FORM

School/Facility Name
Lindop 92 - ESI #5271
ISBE ID: (ex:01-001-0001-01-00001)

Address
Environmental Services, Inc.
P.O. BOX 688
LaGrange, IL 60525
MMDDYY

Sample Collector Name(s)
NM/KP

Water system last used Date: 07/31/2017 Time: 16:00

All samples must be collected in unpreserved

Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" is selected
0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1		LI 1.1	1st Draw CW	08/01/2017	8:00	S - Sink	First Draw	250	
2		LI 1.2	2nd Draw CW	08/01/2017	8:00	S - Sink	Flush	250	
3		LI 1.3	1st Draw HW	08/01/2017	8:00	S - Sink	First Draw	250	
4		LI 2.1	1st Draw CW	08/01/2017	8:02	O - Other	First Draw	250	Drinking Fountain
5		LI 2.2	2nd Draw CW	08/01/2017	8:02	O - Other	Flush	250	Drinking Fountain
6		LI 3.1	1st Draw CW	08/01/2017	8:04	S - Sink	First Draw	250	
7		LI 3.2	2nd Draw CW	08/01/2017	8:04	S - Sink	Flush	250	
8		LI 3.3	1st Draw HW	08/01/2017	8:04	S - Sink	First Draw	250	
9		LI 4.1	1st Draw CW	08/01/2017	8:06	O - Other	First Draw	250	Drinking Fountain
10		LI 4.2	2nd Draw CW	08/01/2017	8:06	O - Other	Flush	250	Drinking Fountain
11		LI 5.1	1st Draw CW	08/01/2017	8:06	S - Sink	First Draw	250	
12		LI 5.2	2nd Draw CW	08/01/2017	8:06	S - Sink	Flush	250	
13		LI 5.3	1st Draw HW	08/01/2017	8:06	S - Sink	First Draw	250	
14		LI 6.1	1st Draw CW	08/01/2017	8:08	O - Other	First Draw	250	Drinking Fountain
15		LI 6.2	2nd Draw CW	08/01/2017	8:08	O - Other	Flush	250	Drinking Fountain
16		LI 7.1	1st Draw CW	08/01/2017	8:10	O - Other	First Draw	250	Drinking Fountain
17		LI 7.2	2nd Draw CW	08/01/2017	8:10	O - Other	First Draw	250	Drinking Fountain
18		LI 8.1	1st Draw CW	08/01/2017	8:11	S - Sink	First Draw	250	
19		LI 8.2	2nd Draw CW	08/01/2017	8:11	S - Sink	Flush	250	
20		LI 8.3	1st Draw HW	08/01/2017	8:11	S - Sink	First Draw	250	
21		LI 9.1	1st Draw CW	08/01/2017	8:12	O - Other	First Draw	250	Drinking Fountain
22		LI 9.2	2nd Draw CW	08/01/2017	8:12	O - Other	Flush	250	Drinking Fountain
23		LI 10.1	1st Draw CW	08/01/2017	8:11	S - Sink	First Draw	250	
24		LI 10.2	2nd Draw CW	08/01/2017	8:11	S - Sink	Flush	250	
25		LI 10.3	1st Draw HW	08/01/2017	8:11	S - Sink	First Draw	250	
26		LI 11.1	1st Draw CW	08/01/2017	8:12	O - Other	First Draw	250	Drinking Fountain
27		LI 11.2	2nd Draw CW	08/01/2017	8:12	O - Other	Flush	250	Drinking Fountain
28		LI 12.1	1st Draw CW	08/01/2017	8:11	S - Sink	First Draw	250	
29		LI 12.2	2nd Draw CW	08/01/2017	8:11	S - Sink	Flush	250	
30		LI 12.3	1st Draw HW	08/01/2017	8:11	S - Sink	First Draw	250	
31		LI 13.1	1st Draw CW	08/01/2017	8:12	O - Other	First Draw	250	Drinking Fountain
32		LI 13.2	2nd Draw CW	08/01/2017	8:12	O - Other	Flush	250	Drinking Fountain
33		LI 14.1	1st Draw CW	08/01/2017	8:11	S - Sink	First Draw	250	
34		LI 14.2	2nd Draw CW	08/01/2017	8:11	S - Sink	Flush	250	
35		LI 14.3	1st Draw HW	08/01/2017	8:11	S - Sink	First Draw	250	
36		LI 15.1	1st Draw CW	08/01/2017	8:12	O - Other	First Draw	250	Drinking Fountain
37		LI 15.2	2nd Draw CW	08/01/2017	8:12	O - Other	Flush	250	Drinking Fountain
38		LI 16.1	1st Draw CW	08/01/2017	8:11	S - Sink	First Draw	250	
39		LI 16.2	2nd Draw CW	08/01/2017	8:11	S - Sink	Flush	250	
40		LI 16.3	1st Draw HW	08/01/2017	8:11	S - Sink	First Draw	250	
41		LI 17.1	1st Draw CW	08/01/2017	8:12	O - Other	First Draw	250	Drinking Fountain
42		LI 17.2	2nd Draw CW	08/01/2017	8:12	O - Other	Flush	250	Drinking Fountain
43		LI 18.1	1st Draw CW	08/01/2017	8:13	S - Sink	First Draw	250	
44		LI 18.2	2nd Draw CW	08/01/2017	8:13	S - Sink	Flush	250	
45		LI 18.3	1st Draw HW	08/01/2017	8:13	S - Sink	First Draw	250	
46		LI 19.1	1st Draw CW	08/01/2017	8:14	O - Other	First Draw	250	Drinking Fountain
47		LI 19.2	2nd Draw CW	08/01/2017	8:14	O - Other	Flush	250	Drinking Fountain
48		LI 20.1	1st Draw CW	08/01/2017	8:15	S - Sink	First Draw	250	
49		LI 20.2	2nd Draw CW	08/01/2017	8:15	S - Sink	Flush	250	
50		LI 20.3	1st Draw HW	08/01/2017	8:15	S - Sink	First Draw	250	
51		LI 21.1	1st Draw CW	08/01/2017	8:16	O - Other	First Draw	250	Drinking Fountain
52		LI 21.2	2nd Draw CW	08/01/2017	8:16	O - Other	Flush	250	Drinking Fountain
53		LI 22.1	1st Draw CW	08/01/2017	8:16	S - Sink	First Draw	250	
54		LI 22.2	2nd Draw CW	08/01/2017	8:16	S - Sink	Flush	250	
55		LI 22.3	1st Draw HW	08/01/2017	8:16	S - Sink	First Draw	250	
56		LI 23.1	1st Draw CW	08/01/2017	8:17	O - Other	First Draw	250	Drinking Fountain
57		LI 23.2	2nd Draw CW	08/01/2017	8:17	O - Other	Flush	250	Drinking Fountain

Resubmitted: 8-2-17 10⁵⁵

KP

Received: 8-2-17 10⁵⁵ AB

58		LI 24.1	1st Draw CW	08/01/2017	8:18	S - Sink	First Draw	250	
59		LI 24.2	2nd Draw CW	08/01/2017	8:18	S - Sink	Flush	250	
60		LI 24.3	1st Draw HW	08/01/2017	8:18	S - Sink	First Draw	250	
61		LI 25.1	1st Draw CW	08/01/2017	8:19	O - Other	First Draw	250	Drinking Fountain
62		LI 25.2	2nd Draw CW	08/01/2017	8:19	O - Other	Flush	250	Drinking Fountain
63		LI 26.1	1st Draw CW	08/01/2017	8:20	S - Sink	First Draw	250	
64		LI 26.2	2nd Draw CW	08/01/2017	8:20	S - Sink	Flush	250	
65		LI 26.3	1st Draw HW	08/01/2017	8:20	S - Sink	First Draw	250	
66		LI 27.1	1st Draw CW	08/01/2017	8:22	O - Other	First Draw	250	Drinking Fountain
67		LI 27.2	2nd Draw CW	08/01/2017	8:22	O - Other	Flush	250	Drinking Fountain
68	206	LI 28.1	1st Draw CW	08/01/2017	8:23	S - Sink	First Draw	250	
69		LI 28.2	2nd Draw CW	08/01/2017	8:23	S - Sink	Flush	250	
70		LI 28.3	1st Draw HW	08/01/2017	8:23	S - Sink	First Draw	250	
71		LI 29.1	1st Draw CW	08/01/2017	8:24	S - Sink	First Draw	250	
72		LI 29.2	2nd Draw CW	08/01/2017	8:24	S - Sink	Flush	250	
73		LI 29.3	1st Draw HW	08/01/2017	8:24	S - Sink	First Draw	250	
74		LI 30.1	1st Draw CW	08/01/2017	8:26	S - Sink	First Draw	250	
75		LI 30.2	2nd Draw CW	08/01/2017	8:26	S - Sink	Flush	250	
76		LI 30.3	1st Draw HW	08/01/2017	8:26	S - Sink	First Draw	250	
77		LI 31.1	1st Draw CW	08/01/2017	8:28	S - Sink	First Draw	250	
78		LI 31.2	2nd Draw CW	08/01/2017	8:28	S - Sink	Flush	250	
79		LI 31.3	1st Draw HW	08/01/2017	8:28	S - Sink	First Draw	250	
80		LI 32.1	1st Draw CW	08/01/2017	8:29	O - Other	First Draw	250	Drinking Fountain
81		LI 32.2	2nd Draw CW	08/01/2017	8:29	O - Other	Flush	250	Drinking Fountain
82		LI 33.1	1st Draw CW	08/01/2017	8:31	S - Sink	First Draw	250	
83		LI 33.2	2nd Draw CW	08/01/2017	8:31	S - Sink	Flush	250	
84		LI 33.3	1st Draw HW	08/01/2017	8:31	S - Sink	First Draw	250	
85		LI 34.1	1st Draw CW	08/01/2017	8:33	S - Sink	First Draw	250	
86		LI 34.2	2nd Draw CW	08/01/2017	8:33	S - Sink	Flush	250	
87		LI 34.3	1st Draw HW	08/01/2017	8:33	S - Sink	First Draw	250	
		LI 35.1	1st Draw CW	08/01/2017	8:34	S - Sink	First Draw	250	
89		LI 35.2	2nd Draw CW	08/01/2017	8:34	S - Sink	Flush	250	
90		LI 35.3	1st Draw HW	08/01/2017	8:34	S - Sink	First Draw	250	
91		LI 36.1	1st Draw CW	08/01/2017	8:35	O - Other	First Draw	250	Drinking Fountain
92		LI 36.2	2nd Draw CW	08/01/2017	8:35	O - Other	Flush	250	Drinking Fountain
93		LI 36A.1	1st Draw CW	08/01/2017	8:36	O - Other	First Draw	250	Drinking Fountain
94		LI 36A.2	2nd Draw CW	08/01/2017	8:36	O - Other	Flush	250	Drinking Fountain
95		LI 36B.1	1st Draw CW	08/01/2017	8:37	O - Other	First Draw	250	Drinking Fountain
96		LI 36B.2	2nd Draw CW	08/01/2017	8:37	O - Other	Flush	250	Drinking Fountain
97		LI 37.1	1st Draw CW	08/01/2017	8:40	S - Sink	First Draw	250	
98		LI 37.2	2nd Draw CW	08/01/2017	8:40	S - Sink	Flush	250	
99		LI 37.3	1st Draw HW	08/01/2017	8:40	S - Sink	First Draw	250	
100		LI 38.1	1st Draw CW	08/01/2017	8:43	O - Other	First Draw	250	Drinking Fountain
101		LI 38.2	2nd Draw CW	08/01/2017	8:43	O - Other	Flush	250	Drinking Fountain
102		LI 39.1	1st Draw CW	08/01/2017	8:44	O - Other	First Draw	250	Drinking Fountain
103		LI 39.2	2nd Draw CW	08/01/2017	8:44	O - Other	Flush	250	Drinking Fountain
104		LI 40.1	1st Draw CW	08/01/2017	8:45	O - Other	First Draw	250	Drinking Fountain
105		LI 40.2	2nd Draw CW	08/01/2017	8:45	O - Other	Flush	250	Drinking Fountain
106		LI 41.1	1st Draw CW	08/01/2017	8:47	O - Other	First Draw	250	Drinking Fountain
107		LI 41.2	2nd Draw CW	08/01/2017	8:47	O - Other	Flush	250	Drinking Fountain
108									
109									
110		LI 44.1	1st Draw CW	08/01/2017		O - Other	First Draw	250	Drinking Fountain
111		LI 44.2	2nd Draw CW	08/01/2017		O - Other	Flush	250	Drinking Fountain
112		LI 45.1	1st Draw CW	08/01/2017		S - Sink	First Draw	250	
113		LI 45.2	2nd Draw CW	08/01/2017		S - Sink	Flush	250	
114		LI 45.3	1st Draw HW	08/01/2017		S - Sink	First Draw	250	
115		LI 46.1	1st Draw CW	08/01/2017		S - Sink	First Draw	250	
116		LI 46.2	2nd Draw CW	08/01/2017		S - Sink	Flush	250	
117		LI 46.3	1st Draw HW	08/01/2017		S - Sink	First Draw	250	
118		LI 47.1	1st Draw CW	08/01/2017		O - Other	First Draw	250	Drinking Fountain
119		LI 47.2	2nd Draw CW	08/01/2017		O - Other	Flush	250	Drinking Fountain
120									
121									
122									
123									
124									
125									
126									
127									

Relinquished; 8-2-17 10⁵⁵

KP

Received; 8-2-17 10⁵⁵ 